IOWA DEPARTMENT OF NATURAL RESOURCES NPDS REPORTING SYSTEM - DISCHARGE MONITORING REPORT

FACILITY INFORMATION

This form is valid 4/1/2015 to 3/31/2020

Facility Name:	SIOUX CITY, CITY OF STP	
Permit #:	9778001	
Month/Year:	9 2017	
Outfall #(s):	001 - DISCHARGE FROM AN ACTIVATED SLUDGE WASTEWATER TREATMENT PLA	NT.
Operator Name:	James Maynes	
Certification #:		6232
Phone #:	712-279-6113	
Lab Cert. #:		323
Comments:	Aeration basin #6 offline/ #1 online 9/27/2017. 9/6/2017 peristalic tube failed on South CL2 11:45AM to 1:45PM. On 9/21/2017, found CL2 line to South contact basin running slow at a CL2 residual at 1:30PM with a Total of .9 and a free of .4. Notified Tom Roos at 1:36PM, to the South basin at 2:00 PM using the drain lift pump. Jetted both North and South lines. with water softner and Culligan made nump adjustments. Had issue again on 9/25/2017 *Include Comments longer than 1000 characters in email	1:00 PM. Did Flow stopped Issue found
Signature:	A- My	
	I certify under penalty of law that this document and all attachments were prepared under supervision in accordance with a system designed to assure that qualified personnel propervaluate the information submitted. Based on my inquiry of the person or persons who ma system, or those persons directly responsible for gathering the information, the information to the best of my knowledge and belief, true, accurate, and complete. I am aware that ther significant penalties for submitting false information, including the possibility of fine and imp known violations.	erly gather and nage the submitted is, e are